

## Schedule 40 PVC Rigid Electrical Conduit US Certification

1/2" through 6" Schedule 40 Rigid Electrical Conduit pipe shall be manufactured in accordance with ANSI/UL 651 and NEMA TC-2. 8" Schedule 40 conduit shall be manufactured in accordance with NEMA TC-2. It shall be manufactured from virgin PVC compound and is grey in color. The standard product is offered in 10 and 20 foot lengths and is joined together by solvent welding. The product is sunlight resistant per UL 651.

1/2" through 6" Schedule 40 Rigid Conduit pipe shall be certified for 90° C wire use per Underwriters Laboratories (UL) 651 and conforms to NEMA TC-2; 8" conduit shall conform to NEMA TC-2 for 75° C wire. Rigid Conduit shall be installed according to the National Electrical Code (NEC) Article 352.

Certifications are based on the applicable edition of the referenced standard in effect on the date of manufacture. If we may be of further assistance, please contact Technical Services at [technical@westlakepipe.com](mailto:technical@westlakepipe.com).

Sincerely,



Joshua E. Clapper  
Director, Product Marketing, Marketing and Development

### Reference Standards:

- **NEMA TC-2** *Electrical PVC Conduit*
- **UL 651** *Schedule 40, 80, Type EB and A Rigid PVC Conduit and Fittings*
- **ASTM D1784** *Standard Specification for Rigid PVC Compounds and CPVC Compounds*